



Annual Performance Report 2024

Permit EPR/KP3936ZB

Tilbury Green Power Plant

other name of facility (if applicable)

Tilbury Green Power Ltd.

Year: 2024

Address: Tilbury Green Power, Port of Tilbury, Tilbury, Essex, RM18 7NU

Tel: [REDACTED]

Email: [REDACTED]

Prepared by: [REDACTED] Position: QHSE Advisor

Approved by: [REDACTED] Position: Senior General Manager

Version: 1

Issue Date: 31/01/2025

Contents		
Section	Subject	Page
	Facility Information	
	Operational Data	
	Operational Summary	
	Performance Form 1	
	Energy Form 1	
	Permit Compliance	
	Improvements	
	Public Liaison	
	Carbon dioxide and nitrous oxide emissions	
	Residue Quality	
	Emissions to Water	
	Emissions to Air (periodically monitored)	
	Emissions to Air (continuously monitored)	
	Hydrogen Chloride emissions	
	Sulphur Dioxide emissions	
	Oxides of Nitrogen emissions	
	Total Organic Carbon emissions	
	Particulate Matter emissions	
	Carbon Monoxide emissions	
	Ammonia emissions	

Version Control		
Section	Information	Date

Distribution		
Copy	Name, Role	No.

This report is required under the Industrial Emissions Directive's Article 55(2) requirements on reporting and public information on waste incineration plants and co-incineration plants, which require the operator to produce an annual report on the functioning and monitoring of the plant and make it available to the public.

Plant Description and Design

The Woodchip Storage Building receives woodchip from the Wood Processing Building via an enclosed Woodchip Transfer Conveyor, or directly by road trailer via the Woodchip Storage Building's Woodchip Reception Bays, and feeds woodchip to the boiler via the Boiler Feed Conveyor. The Woodchip Storage Building stores up to 14,400 m³ (3,025 tonnes) of woodchip, sufficient to supply the boiler for around 3.5 days. Processed woodchip is held within the Woodchip Storage Building for a maximum of 8 weeks. The boiler requires around 1,381,000 m³/year (290,000 tonnes/year) of woodchip and produces around 40.3 MWe.

Summary of Operational Processes and Procedures

Waste wood is received and processed on site. The combustion process employs a single travelling grate system, with the hot combustion gases passing through a boiler. The steam generated in the boiler is fed to a steam turbine which in turn drives a generator to produce electricity. Equipment within the Flue Gas Treatment Area is provided to minimise emissions to air, and comprises of selective non-catalytic reduction for control of oxides of nitrogen (by injection of urea into the furnace chamber); a multi-compartment fabric filter (for particulate matter (i.e. dust) control); dry lime (for control of acid gases by injection of lime into the exhaust gas stream prior to the fabric filters); and activated carbon (for control of dioxins, furans and metals by injection of activated carbon into the exhaust gas stream prior to the fabric filters) Whilst activated carbon has been available on site to date there has not been a need to use it in order to control dioxins, furans and metals within the exhaust gas stream. Treated flue gases are monitored and released via a 100 metre high stack.

Solid residues in the form of bottom ash (from the boiler) and fly ash (from the flue gas treatment system) are stored on site (within the Bottom Ash Store and Fly Ash Silo respectively) for subsequent removal off-site to an appropriately licenced waste management facility. Process effluents are generated from boiler blow down and the water treatment plant and equipment, are collected and treated in the sedimentation tank. Treatment provides acid dosing for pH adjustment and settlement of solids prior to discharge to sewer under a trade effluent consent. Uncontaminated surface water run-off will be collected in the surface water drainage system. Where possible it will be harvested for domestic use within the Power Plant Facility, with the remainder being discharged to the Botney Channel watercourse.

Operational Data

Plant Size	320,000 tonnes pa	116 MWth	40
No. of combustion lines	1	No. of Turbines:	1

Waste types received	Unit	Q1	Q2	Q3	Q4	Year Total
Household / Local Authority	tonnes					-
Commercial & Industrial						-
Hazardous						-
Clinical						-
Waste wood (biomass)		72,284	63,711	36,997	55,200	228,192
Refuse Derived Fuel * - H'hold/LA						-
Refuse Derived Fuel * - C&I						-
Other [Please specify]						-
Other [Please specify]						-
Other [Please specify]						-
Total waste received			72,284	63,711	36,997	55,200
Rejected Waste		21	11	8	11	52
Unprocessed waste transferred out						-
Total waste combusted **		72,284	63,711	36,997	55,200	228,192

Energy Usage / Export	Unit	Q1	Q2	Q3	Q4	Year Total
Power Generated	MWh	90,733	81,887	48,086	70,322	291,028
Power Exported		85,071	76,737	45,055	65,935	272,797
Power Used on site		5,662	5,150	3,031	4,387	18,231
Power Imported		45	208	552	480	1,285
Parasitic Load	%	6.3%	6.5%	7.4%	6.9%	6.7%
Thermal Energy Produced ***	MWh					-
Thermal Energy Exported ***	MWh					-
R1 value (if applicable)	R1					

Waste Disposal & Recovery	Unit	Q1	Q2	Q3	Q4	Year Total
APC Residues - produced	tonnes	1,543	1,360	790	1,066	4,758
IBA - produced		4,483	3,951	2,294	3,432	14,160
Metals recycling		41	38	19	33	131
Other		-	-	-	-	-
Other		-	-	-	-	-
Other		-	-	-	-	-

Raw Material Usage	Unit	Q1	Q2	Q3	Q4	Year Total
Mains Water	ltrs	13,687,000	13,669,000	12,238,000	8,915,000	48,509,000
Other Water	ltrs					-
Ammonia	kgs					-
Urea	kgs	66,412	55,942	40,614	67,471	230,439
Activated Carbon	kgs					-
Lime / hydrated lime	kgs	872,461	611,814	322,629	558,227	2,365,131
Fuel oil	ltrs	210,217	225,184	220,504	272,194	928,099
Gas	cuf					-
Other						-

Summary	Line/Unit	Q1	Q2	Q3	Q4	Year Total
	1	2,076	1,914	1,145	1,702	6,837
Availability of waste combustion by line, hrs ****	2					
	3					
	4					
	5					
Overall Availability, mean avg. of all lines, hrs		2,076	1,914	1,145	1,702	6,837
Hours of turbine operations, hrs	1	2,045	1,995	1,152	1,734	6,926
Hours of turbine operations, hrs	2					-
Hours of heat / steam export						-
Net Calorific Value of waste	MJ/kg					
Abnormal Events	qty.					-
Abnormal operation	hours		3			3
Permit Breaches	qty.		1	1	2	4

MWe

%
-
-
-
-
100.0%
-
-
-
-
-
0.0%
-

KWh/te
1,275
1,195
80
6
-
-

% inputs
2.1%
6.2%
0.1%
-
-
-

kg or Ltr /te
212.58
-
-
1.01
-
10.36
4.07

78.0%
0.0%
0.0%
0.0%
0.0%
78.0%
79.1%
0.0%
n/a
no
0.0%
yes

Summary of Plant Operations and Maintenance during the reporting year

The plant entered 2024 in full commercial operation following the O&M contract guidelines. During 2024 the focus was to plan and execute a major maintenance outage during September as two large projects were required to replace the furnace grate and superheater bundles 1B and 2A within the superheater section of the boiler. Following a challenging year in 2023 with boiler tube leaks, plant reliability was seen to improve during Q1 of 2024, following the detailed boiler inspection and repairs conducted in 2023.

During Q1 the plant operated very well, achieving high availability for the first two and half months of the year with only minor load losses due to fuel related issues and some minor plant problems, however the first tube leak event of 2024 occurred during March in the superheater caused a three day shutdown event, with further tube leak events each month thereafter. It was apparent that superheaters 1B and 2A due for replacement were starting to deteriorate significantly, as during July three tube leak events occurred during the month with the final event of the month rolling into August and a further two leak events occurring during August.

The annual outage in September was split into two separate critical paths to accommodate the WBOC scope of works and the TGP improvement works to replace superheaters 1B and 2A, the WBOC scope of work duration was set at 20 days and the overall outage duration to replace the two superheaters was set at 34 days inclusive of the WBOC scope of work. The outage was completed successfully but was delayed following a boiler inspection that identified some thin tubes were identified which slowed the progress of the superheater installation as the connection points to superheater 1B had to be replaced. There were also some other challenges with the superheater installation which slowed progress, so the overall installation time was extended by six days.

After completion of the outage the plant was restarted successfully, however following restart several grate bars detached from the grate due to not being secured correctly which required a 24 hour stop to rectify.

After completion of the outage and returning to normal operation the plant struggled to achieve maximum output for a short period of time due to a very clean boiler (lack of fouling) and the grate being replaced, which required detailed air flow/combustion tuning. AET supported the site post outage to optimize combustion so full load could be achieved as quickly as possible.

Following combustion optimisation, the plant started to operate reliably and some steady state operation was

Summary of Residue Handling for the reporting year

Both IBA and APCR have been handled as hazardous waste. IBA has been sent to Augean ENRMF Kings Cliffe, or Augean Thornhaugh Landfill Site. APCR has been sent to OCO Technology in Thetford or OCO Technology Avonmouth who have a carbon capture utilisation process which treats and stabilises the APCR which can then be used as sustainable construction products. Full details can be found in the quarterly waste returns which have been completed and submitted throughout 2024.

2024 Annual Reporting Performance Form 1

Permit EPR/KP3936ZB

Operator: Tilbury Green Power Ltd.

Facility: Tilbury Green Power Plant

Form: Performance 1

Reporting Period from:

01 January 2024

to:

31 December 2024

2024 Annual Reporting of Waste Disposal and Recovery

Waste Description	Disposal Route(s)	Disposal Tonnes	Recovery Tonnes	% / tonne of waste incinerated
1) Hazardous Wastes				
APC Residues	R05	0.0	5,333.6	2.3%
IBA	D01	15,061.4	0.0	6.6%
				-
				-
Total Hazardous Waste		15,061.4	5,333.6	8.9%
2) Non-Hazardous Wastes				
IBA				-
Ferrous Metal				-
Process Water				-
				-
				-
Total Non-Hazardous Waste		0.0	0.0	-
TOTAL WASTE		15,061.4	5,333.6	8.9%

Operator's comments :

Ferrous metal is now transferred to Eskens Renewables for onward disposal/recycling and is included within the relevant reports submitted by Eskens Renewables.

2024 Annual Reporting of Water and Other Raw Material Usage

Raw Material	Usage	Unit	Specific Usage	Unit
Mains Water	48509	m ³	0.21	m ³ /te
Total Water	48509	m ³	0.21	m ³ /te
Urea / Ammonia	0	kg	-	kg/te
Activated Carbon	0	kg	-	kg/te
Lime / hydrated lime / Sodium Bicarb.	2365131	kg	10.36	kg/te

Operator's comments :

2024 Annual Reporting of other performance indicators

Parameter	Results by Line					Turbine 1	Turbine 2
	A1	A2	A3	A4	A5		
Operating hours for the year, hours	6837					6926	
Number of periods of abnormal operation, qty.	1						
Cumulative hours of abnormal operation for this year, hours	2.5						

Operator's comments :

Abnormal operating period took place on 19/05/2024 and a schedule 5 part A & B previously submitted

Signed: _____

Date: _____

2024 Annual Reporting of Energy Usage/Export

Permit EPR/KP3936ZB

Operator: Tilbury Green Power Ltd.

Facility: Tilbury Green Power Plant

Form: Energy 1

Reporting Period from: 01 January 2024

to: 31 December 2024

Energy Source	Energy Usage	Unit	Specific Usage (KWh/tonne incinerated)
Electricity Produced	291,028	MWh	1275
Electricity Imported	1285.33	MWh	6
Electricity Exported	272,797	MWh	1195
Gas Oil		tonnes	
Steam/hot water exported	0	GWh	-

Operator's comments :

Signed: _____

Date: _____

Summary of Permit Compliance

Compliance with permit limits for continuously monitored pollutants

The plant met its emission limits as shown in the table below:

Substance	Percentage time compliant during operation ^{Note 1}	
	Half-hourly limit	Daily limit
Particulates	100%	100%
Oxides of nitrogen	100%	100%
Sulphur dioxide	100%	100%
Carbon monoxide	100%	99%
Total organic carbon	100%	100%
Hydrogen chloride	100%	100%
Hydrogen fluoride	100%	100%
	xx.xx %	xx.xx %

Summary of non-compliances under the permit ^{Note 2}

Date	Summary of non-compliance ^{Note 3}	Reason	Measures taken to prevent reoccurrence	CC
				Impact
CAR Report 31/03/2024	None	N/A	N/A	N/A
CAR 30/09/2024	IBA result for TOC was in exceedance at 4.91%	Sample taken from startup ash and not during steady state operation	Sampling only to be done on ash from steady state operation (base load)	C4
CAR 30/09/2024	Failure to submit schedule 5 in accordance with timescale required	Internal review of lab report for IBA sampling was not undertaken and therefore breach was not identified.	Internal management review of lab reports and quarterly reports prior to submission to the EA.	C4
CAR 30/09/2024	Failure to follow management system in respect of reporting non compliances and IBA sampling & Testing Protocol V2.1 June 2023	Human error and refamililarisation of associated protocol required	Personnel responsible for collecting IBA samples and reporting both results and/or breaches, retrained on the 'IBA Sampling & Testing Protocol - V2.1 June 2023.	C4

Limit Breach TOC 27/09/2024	IBA result for TOC was in exceedance at 4.91%	Sample taken from startup ash and not during steady state operation	Sampling only to be done on ash from steady state operation (base load)	-
ELV Breach CO 11/10/2024	Exceedance of CO daily average at 96.07 mg/nm3	Missing travelling grate elements resulting in unstable combustion and CO spikes	The grate will be overhauled every 5-6 years so to prevent recurrence next replacement of grate elements to include a final QA check on the grate bar split pins to ensure all the grate bars have been secured properly and are secure for operation.	-
ELV Breach CO 21/11/2024	Exceedance of CO daily average at 94.2 mg/nm3	Multiple CO spikes when co- firing on aux burners and further spikes during the day resulting in overall daily average exceedance	DCS software modified so the fuel trimmer corrects itself automatically when a plant start is initiated to eliminate human error	-
CAR Report 26/11/2024	None	N/A	N/A	N/A
ELV Breach CO 22/12/2024	Exceedance of CO daily average at 99.9 mg/nm3	Multiple CO spikes when co- firing on aux burners and further spikes during the day resulting in overall daily average exceedance	DCS software modified so the fuel trimmer corrects itself automatically when a plant start is initiated to eliminate human	-

*If the Environment Agency (EA) has given a Compliance Classification Scheme (CCS) score due to a should be entered here (CCS4 = No impact; CCS3 = Minor impact; CCS2 = Significant impact; CCS1 = has not yet assessed a non-compliance which you have notified to them, these columns should be left

Summary of any complaints received and actions to taken to resolve			
Date	Summary of complaint [including Line/Reference]	Reason (including whether substantiated by the operator or the EA)	Mea

24 July 2024	Received through EA officer Gail Harvey. Dust reported to be clogging filter on rooves and covering cars.	The caller described the dust as a brown/beige colour. More like a fibre but can vary, particle size can be different. Caller stated this is not just a cost to them but raised concerns they are breathing it in. It was first noticed yesterday evening (23rd July) but reported as an ongoing issue.	Investiga Operator dust sup It was no of the du bowser v improve cannon v maintena now fully The Ope major ou During th system v perimete control.

ie 1
it

OS score if applicable*
Root cause
N/A
Sample taken from non steady state operation IBA
Lab reports were not subject to internal management review prior to inclusion in the associated quarterly report to the EA
Periodic refamiliarisation of associated IBA Sampling & Testing Protocol V2.1 June 2023.

Sample taken from non steady state operation IBA
Grate element's split pins not fully QA inspected
Fuel feed trimmer adjusting incorrectly and feeding around 35% more fuel than required resulting in iunstable combustion, until it ramped down in automatic control,
N/A
Fuel feed trimmer adjusting incorrectly and feeding around 35% more fuel than required resulting in iunstable combustion, until it ramped down in automatic control,

permit non-compliance it = Major impact). If the EA blank.

ve them.

asures taken to prevent reoccurrence

tion completed on the
: It was observed that the
pression equipment was on.
ted that the water flow to one
st cannons was poor. A
was brought to site to help
dust control while the faulty
was undergoing
ance. The misting cannon is
back in service.
rator will be shut down for a
tage in September 2024.
is outage a full fogging
will be installed on the
r walls to improve dust

Summary of Plant Improvements

Summary of any efficiency improvements that have been completed within the year.

Throughout 2024 the plant has continued to improve the combustion within the boiler, for the purposes of increasing efficiency, reducing fouling and decreasing emissions.

Identified passing valves and repaired them during the annual maintenance outage to improve water consumption and reduce energy loss.

Travelling grate within the boiler replaced during September 2024 maintenance outage, improving combustion back to as new standard.

Summary of any permit improvement conditions that have been completed within the year and the resulting environmental benefits.

All permit improvement conditions completed and submitted successfully. Ongoing environmental benefits to be monitored.

Summary of any changes to the plant or operating techniques which required a variation to the permit and a summary of the resulting environmental impact.

N/A

Summary of any other improvements made to the plant or planned to be made and a summary of the resulting environmental benefits.

Sediment filters have been installed on surface water drains across site to reduce blockages and risk of site flooding.

Details of Public & Stakeholder Liaison

Summary of events held during the reporting year.	
Date	Description
Apr-24	A newsletter was issued to the local residents and identified local stakeholder groups.

List of events planned for next year	
Date	Description

If you wish to be involved in the public liaison programme, please contact _____

Carbon dioxide emissions and biogenic content of waste inputs

Carbon dioxide emissions (all types of plant)

Annual mass of carbon dioxide released	353,897 tonnes
Annual mass of carbon dioxide released per tonne of waste burned	1.55 t CO ₂ / t waste
Annual mass of carbon dioxide released per MWh of energy exported	1.29 t CO ₂ / MWh export
Description of how annual carbon dioxide mass emission has been calculated. See Note 1	<ol style="list-style-type: none"> 1. Calculate total hourly flow rate. 2. Divide average CO₂ percentage by 10 3. Calculate grams of CO₂ using avogadro 4. Convert total to tonnes by dividing by 1

Nitrous oxide emissions (only plants which use ammonia or urea to abate NOx emissions)

Annual mass emissions of nitrous oxide	0.706 tonnes N ₂ O
Description of how annual nitrous oxide mass emission has been calculated See Note 2	<ol style="list-style-type: none"> 1. Sum of all 30 minute values for 2024, in kg, 2. Divide result by 1000 to convert to tonnes
Total annual carbon dioxide + nitrous oxide emissions. Note 3.	354,084.09 tonnes CO ₂ e

Biogenic CO2 emissions (See Note 4)

Percentage of total carbon dioxide emissions arising from biogenic waste	%
No. of measurements undertaken	Number
Description of how percentage biogenic carbon dioxide emissions have been measured or calculated. See Note 5	

Biogenic fraction of waste feedstock (See Note 4)

Yearly average biogenic percentage of the waste by net calorific value (NCV)	%
--	---


Description of how biogenic percentage (by NCV) has been calculated or estimated. See Note 6	
Yearly average biogenic percentage of the waste by mass	%
If waste sampling undertaken, no. of samples used to ascertain average biogenic percentages above	Number
Description of how biogenic percentage (by mass) has been calculated or estimated. See Note 7	

0 and multiply by total hourly flow rate. ros law. l,000,000.

s)

divided by 2 to provide annual emission in nes.

--



Residue Quality Monitoring Requirements

Summary of monitoring undertaken and compliance
Quarterly samples of incinerator bottom ash and fly ash collected and sent for lab analysis
Biannual onsite monitoring undertaken by SOCOTEC.

Commentary on any specific events

Date & Event	Description

Residue Quality Monitoring Results			
Parameter (unit)	Limit*	Normal Operation	
		Bottom ash	APC Residues
Loss on Ignition (average %)	<5%	2.42	
Total Organic Carbon (average %)	<3%	2.85	
No. of Assessments Undertaken	---	Quarterly when in operation	
No. of Hazardous Results	---	N/A	

* The permit will specify a limit of either 5% loss on ignition or 3% total organic carbon. If both are measured anyway, please enter the results here, even where the limit does not apply.

Comments :
Bottom Ash quarterly results for loss on ignition: Q1 - 3.3 Q2 - 2.0 Q3 - 3.2 Q4 - 1.2

Emissions to Water

Summary of monitoring undertaken and compliance
There is no environmental permit conditions for trade effluent. A trade effluent consent is in place with Anglian water
Anglian Water attend site on a quarterly basis to conduct sampling and testing of the trade effluent.
WBOC undertake sampling of the neutralisation pit (trade effluent water) on a weekly basis to create a monthly composite sample which is then sent to an accredited lab to ensure it is compliant with the consent.

Commentary on any specific events
--

Date & Event	Description

Emissions to Water / Sewer

Parameter	Monitoring Frequency	Limit	Target	Max.	Average

Emissions to Air (periodically monitored)

Summary of monitoring undertaken, standards used and compliance
Biannual MCERTS accredited monitoring undertaken by Socotec.

Results of emissions to air that are periodically monitored - oxygen reference 6%							
Substance	Ref. Period	Emission Limit Value	Average				
			A1	A2	A3	A4	A5
Hydrogen fluoride	1 hr	1.5 mg/m ³	0.081				
Cd and Tl and their compounds	0.5-8hrs	0.03 mg/m ³	0.00081				
Hg and its compounds	0.5-8hrs	0.03 mg/m ³	0.00044				
Sb, As, Pb, Cr, Co, Cu, Mn, Ni, V and their compounds	0.5-8hrs	0.45 mg/m ³	0.017				
Dioxins & Furans (I-TEQ)	6-8hrs	0.09 ng/m ³	0.00095				
PCBs (WHO-TEQ Humans / Mammals)	6-8hrs	None set ng/m ³	0.00017				
PCBs (WHO-TEQ Fish)	6-8hrs	None set ng/m ³	0.000012				
PCBs (WHO-TEQ Birds)	6-8hrs	None set ng/m ³	0.00069				
Dioxins & Furans (WHO-TEQ Humans / Mammals)	6-8hrs	None set ng/m ³	0.00091				
Dioxins & Furans (WHO-TEQ Fish)	6-8hrs	None set ng/m ³	0.0085				
Dioxins & Furans (WHO-TEQ Birds)	6-8hrs	None set ng/m ³	0.0016				
Anthanthrene	6-8hrs	None set µg/m ³	0.0013				
Benzo(a)anthracene	6-8hrs	None set µg/m ³	0				
Benzo(a)pyrene	6-8hrs	None set µg/m ³	0.0013				
Benzo(b)fluoranthene	6-8hrs	None set µg/m ³	0				
Benzo(b)naphtho(2,1-d)thiophene	6-8hrs	None set µg/m ³	0				
Benzo(c)phenanthrene	6-8hrs	None set µg/m ³	0.0013				
Benzo(ghi)perylene	6-8hrs	None set µg/m ³	0.0013				
Benzo(k)fluoranthene	6-8hrs	None set µg/m ³	0.0013				
Cholanthrene	6-8hrs	None set µg/m ³	0.0013				
Chrysene	6-8hrs	None set µg/m ³	0.01				
Cyclopenta(cd)pyrene	6-8hrs	None set µg/m ³	0.0013				
Dibenzo(ai)pyrene	6-8hrs	None set µg/m ³	0.0013				
Dibenzo(ah)anthracene	6-8hrs	None set µg/m ³	0.0013				
Fluoranthene	6-8hrs	None set µg/m ³	0.09				
Indeno(123-cd) pyrene	6-8hrs	None set µg/m ³	0.0013				
Naphthalene	6-8hrs	None set µg/m ³	0.07				
Comments :							

Emissions to Air (continuously monitored)

Summary of monitoring undertaken, standards used and compliance												

Results of emissions to air that are continuously monitored (maximum and average values for each line) - oxygen reference 6%												
Substance	Reference Period	Emission Limit Value	A1		A2		A3		A4		A5	
			Max.	Avg.	Max.	Avg.	Max.	Avg.	Max.	Avg.	Max.	Avg.
Oxides of nitrogen	Daily mean	270 mg/m ³	228.3	199.9								
	½ hourly mean*	600 mg/m ³ *	307.07	201.8								
Particulates	Daily mean	7.5 mg/m ³	5.5	0.1								
	½ hourly mean*	45 mg/m ³ *	40.9	0.08								
Total Organic Carbon	Daily mean	15 mg/m ³	1.5	0.6								
Hydrogen chloride	Daily mean	12 mg/m ³	4.07	0.7								
	½ hourly mean*	90 mg/m ³ *	6.4	0.8								
Sulphur dioxide	Daily mean	60 mg/m ³	57.9	46.4								
	½ hourly mean*	300 mg/m ³ *	182.9	47.4								
Carbon monoxide	Daily mean	75 mg/m ³	99.9	41.6								
Ammonia	Daily mean	22.5 mg/m ³	21.1	1.4								

* = delete if your plant does not have these limits

Comments :


--

Monitoring of Hydrogen Chloride emissions

Whole Installation

See Notes in Cell Q3

2024	1/2 Hourly Reference Periods			Daily Reference Periods			
	mg/Nm ³	1/2 hourly HCl ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily HCl ELV	Monthly mean of daily averages	Highest daily average
Jan	90	90	0.46	3.6	12	0.4	1.2
Feb	90	90	0.5	5.1	12	0.5	1.3
Mar	90	90	0.4	2.05	12	0.4	1.1
Apr	90	90	0.6	3.5	12	0.6	1.4
May	90	90	0.7	3.2	12	0.7	1.5
Jun	90	90	1.3	4.6	12	1.3	2.5
Jul	90	90	1.7	6.4	12	1.7	4.07
Aug	90	90	1.1	4.4	12	1.1	2.4
Sep	90	90	0	0	12	0	0
Oct	90	90	0.3	1.4	12	0.3	0.7
Nov	90	90	0.6	3.1	12	0.6	1.2
Dec	90	90	0.5	5.5	12	0.5	1.3




Comments :

Monitoring of Sulphur dioxide emissions

Whole Installation

See Notes in Cell Q3

2024	1/2 Hourly Reference Periods			Daily Reference Periods		
	1/2 hourly SO2 ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily SO2 ELV	Monthly mean of daily averages	Highest daily average
Jan	300	48.5	135.3	60	48.5	57.9
Feb	300	48.4	117.4	60	48.4	50.9
Mar	300	48.2	121.1	60	48.2	51.4
Apr	300	47.1	107.1	60	47.1	49.6
May	300	46.6	99.7	60	46.6	48.8
Jun	300	44.1	182.9	60	44.1	52.7
Jul	300	49.2	85.1	60	49.2	53.8
Aug	300	46.7	101.5	60	46.7	54.3
Sep	300	5.01	6.7	60	5.01	5.01
Oct	300	46.3	84.3	60	46.3	48.8
Nov	300	47.3	177.8	60	47.3	57.7
Dec	300	48.1	120.8	60	48.1	52.8




Comments :

Monitoring of Oxides of Nitrogen emissions

Whole Installation

See Notes in Cell Q3

2024 mg/Nm ³	1/2 Hourly Reference Periods			Daily Reference Periods		
	1/2 hourly NOx ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily NOx ELV	Monthly mean of daily averages	Highest daily average
Jan	600	201.3	247.1	270	201.3	225.7
Feb	600	205.9	264.7	270	205.9	215.6
Mar	600	207.8	233.09	270	207.8	214.4
Apr	600	193.6	242.7	270	193.6	212.6
May	600	202.8	248.9	270	202.8	212.7
Jun	600	185.5	244.3	270	185.5	207.6
Jul	600	206.07	261.7	270	206.08	228.3
Aug	600	208.5	266.7	270	208.5	218.2
Sep	600	208.2	244.5	270	208.2	208.2
Oct	600	190.1	307.07	270	190.1	213.6
Nov	600	204.3	251.6	270	204.3	215.2
Dec	600	204.9	245.6	270	204.9	214.7




Comments :

Monitoring of Total organic carbon emissions Whole Installation

See Notes in Cell Q3

2024	1/2 Hourly Reference Periods			Daily Reference Periods		
	1/2 hourly TOC ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily TOC ELV	Monthly mean of daily averages	Highest daily average
Jan	None	0.9	1.3	15	0.9	1
Feb	None	0.9	1.9	15	0.9	1.03
Mar	None	0.9	1.5	15	0.9	1
Apr	None	0.9	1.5	15	0.9	1.05
May	None	0.9	1.3	15	0.9	0.9
Jun	None	0.9	2.1	15	0.9	1.3
Jul	None	0.2	6	15	0.2	0.9
Aug	None	0.1	5.2	15	0.1	0.5
Sep	None	0.1	0.3	15	0.1	0.1
Oct	None	0.1	2.8	15	0.1	1.5
Nov	None	0.1	5.6	15	0.1	1.02
Dec	None	0.1	1.4	15	0.1	0.8




Comments :

Monitoring of Particulate matter emissions

Whole Installation

See Notes in Cell Q3

2024	1/2 Hourly Reference Periods			Daily Reference Periods		
	mg/Nm ³	1/2 hourly PM ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily PM ELV	Monthly mean of daily averages
Jan	45	0.01	0.5	7.5	0.01	0.03
Feb	45	0.006	0.28	7.5	0.006	0.01
Mar	45	0.1	22.6	7.5	0.1	3.07
Apr	45	0.1	17.04	7.5	0.1	5.5
May	45	0.05	24.2	7.5	0.05	1.3
Jun	45	0.1	28.01	7.5	0.1	3.7
Jul	45	0.1	9.6	7.5	0.1	2.2
Aug	45	0.1	20.2	7.5	0.1	5.5
Sep	45	0.1	1.5	7.5	0.1	0.1
Oct	45	0.1	40.9	7.5	0.1	3.6
Nov	45	0.09	9.3	7.5	0.09	1.5
Dec	45	0.02	3.1	7.5	0.02	0.2



Comments :


Monitoring of Carbon Monoxide (half hourly)

Whole Installation

See Notes in Cell Q3

If your plant has no short-term (half-hourly or 10-minute) CO ELVs, please complete this tab (stating "none" in the 1/2 hourly CO column) and ignore the CO 95% 10 min tab; otherwise, complete the relevant CO tab for your plant

2024 mg/Nm ³	1/2 Hourly Reference Periods			Daily Reference Periods		
	1/2 hourly CO ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily CO ELV	Monthly mean of daily averages	Highest daily average
Jan	None	-	-	75	31.1	34.9
Feb	None	-	-	75	30.5	37.3
Mar	None	-	-	75	29.7	34.6
Apr	None	-	-	75	34.9	40.3
May	None	-	-	75	34.2	38.3
Jun	None	-	-	75	37.05	48.2
Jul	None	-	-	75	44.8	70.4
Aug	None	-	-	75	50.08	58.5
Sep	None	-	-	75	55.2	55.2
Oct	None	-	-	75	64.8	96.07
Nov	None	-	-	75	56.4	94.2
Dec	None	-	-	75	50.4	99.9



Comments :


Monitoring of Carbon Monoxide (10-minute avg)

Whole Installation

See Notes in Cell S3

If your plant has no short-term (half-hourly or 10-minute) CO ELVs, please ignore this tab and instead complete the CO 0.5 hourly tab; otherwise, please complete the relevant CO tab for your plant

2024 mg/Nm ³	10-minute Reference Periods				Daily Reference Periods		
	95%ile 10-min avg CO ELV	Highest daily 95%ile 10-min average	Monthly mean of 10-min averages	Highest 10-min average	Daily CO ELV	Monthly mean of daily averages	Highest daily average
Jan	ELV or none				75		
Feb	ELV or none				75		
Mar	ELV or none				75		
Apr	ELV or none				75		
May	ELV or none				75		
Jun	ELV or none				75		
Jul	ELV or none				75		
Aug	ELV or none				75		
Sep	ELV or none				75		
Oct	ELV or none				75		
Nov	ELV or none				75		
Dec	ELV or none				75		




Comments :
 Environment Agency explanatory note: The 10-minute average ELV is based on the "95th percentile". In this case this means that 95% of the 10 minute averages in the relevant 24-hour period (i.e. 137) must be below 150 mg/Nm3, and 5% (i.e. 7) are allowed to be any value above 150 mg/Nm3. Whilst we expect operators to minimise CO emissions at all times, it is perfectly acceptable for the value of the maximum 10-minute average to be above 150 mg/Nm3, provided the 95th percentile ELV has been met for that period.

Monitoring of Ammonia emissions

Whole Installation

See Notes in Cell Q3

2024	1/2 Hourly Reference Periods			Daily Reference Periods		
	1/2 hourly NH3 ELV	Monthly mean of half-hourly averages	Highest half-hourly average	Daily NH3 ELV	Monthly mean of daily averages	Highest daily average
Jan	None	0.6	30.01	22.5	0.6	2.3
Feb	None	0.6	11.4	22.5	0.6	1.2
Mar	None	0.44	0.5	22.5	0.6	3.3
Apr	None	0.8	14.8	22.5	0.8	4.4
May	None	0.7	24.3	22.5	0.7	2.3
Jun	None	0.8	21.9	22.5	0.8	5.1
Jul	None	0.9	26.8	22.5	0.9	4.8
Aug	None	0.8	77.9	22.5	0.8	6.8
Sep	None	0.8	1.07	22.5	0.8	0.8
Oct	None	7.06	207.5	22.5	7.06	21.1
Nov	None	1.1	21.1	22.5	1.1	11.8
Dec	None	1.05	58.6	22.5	1.05	5.1



Comments :

An indicated ELV value of zero in the table above means that no ammonia limit is/was set in the permit.

Log of changes to

Date
23/09/2024
23/09/2024
23/09/2024
23/09/2024
23/09/2024
23/09/2024
08/11/2024
08/11/2024
08/11/2024
08/11/2024
27/11/2024

template (Environment Agency use only)

Description of change
Air (periodic) tab: corrected symbol for Thallium to Tl
Air (periodic) tab: removed last year's references to different emission limit values applying from 03/12/23 and updated all relevant ELVs
Tabs for continuously monitored pollutants (HCl, SO2 etc.): changed terminology in table headings to improve clarity
Tabs for continuously monitored pollutants (HCl, SO2 etc.): removed last year's references to different emission limit values applying from 03/12/23 and updated all relevant ELVs
Perf 1 tab: updated formula for water usage to report m3 rather than litres and corrected error with formula copying operator name
CO2 N2O tab: various changes made to notes to reflect the fact that most plants should now have calibrated CEMS and flow meters + some have C14 samplers and more up to date industry data
CO2 N2O tab: Changed the N2O CO2 equivalence factor from 298 to 265 in line with recently updated government greenhouse gas figures: https://www.gov.uk/government/publications/greenhouse-gas-reporting-conversion-factors-2024
CO2 N2O tab: Added an additional requirement for municipal EfW plants to state the yearly average biogenic percentage of the waste by mass, and reference to a document which sets out a methodology for calculating NCV of waste from the results of C14 sampling.
Permit Compliance tab: Two additional columns added + explanatory notes to the table entitled "Summary of non-compliances under the permit" to allow CCS scores to be stated where relevant.
Residue Quality tab: Note added explaining application of TOC and LOI limits and asking operators to report both metrics where measured.
Operational Summary tab: table added on start-ups and shut-downs

New version number and date
Version 24b (for co-incinerators) - 23/09/24
Version 24.1b (for co-incinerators) - 08/11/24
Version 24.2b (for co-incinerators) -27/11/24